

Período Febrero 2018

Fecha	Sector	Superficie (há)	Lectura inicial M3	Lectura Final M3	Tiempo de Disposición (minutos)	N° aspersores/ Carrete Movil	M3 Dispuestos (m³/día)	pH	DBO5	Carga aplicada (Kg DBO <sub>5</sub> / ha*día)	Carga máxima permitida (Kg DBO <sub>5</sub> / ha*día)	% Dispuesto	Margen de seguridad (%)
1-feb-18	2	4	52,408	52,583	192	1	175	6.6	1,093	47.82	112	42.70	57.30
2-feb-18	2	4	52,583	52,759	193	1	176	5.8	1,093	48.09	112	42.94	57.06
3-feb-18													
4-feb-18													
5-feb-18	2	4	52,759	52,917	174	1	158	7	1,093	43.17	112	38.55	61.45
6-feb-18	2	4	52,917	53,072	170	1	155	7	1,093	42.35	112	37.82	62.18
7-feb-18	2	4	53,072	53,232	176	1	160	6.6	1,093	43.72	112	39.04	60.96
8-feb-18	2	4	53,232	53,381	164	1	149	8.4	1,093	40.71	112	36.35	63.65
9-feb-18													
10-feb-18													
11-feb-18	2	4	53,381	53,544	179	1	163	6.4	1,093	44.54	112	39.77	60.23
12-feb-18	2	4	53,544	53,729	203	1	185	6.3	1,093	50.55	112	45.14	54.86
13-feb-18	2	4	53,729	53,894	181	1	165	6.5	1,093	45.09	112	40.26	59.74
14-feb-18	2	4	53,894	54,004	121	1	110	7	1,093	30.06	112	26.84	73.16
15-feb-18	2	4	54,004	54,129	137	1	125	6.7	1,093	34.16	112	30.50	69.50
16-feb-18													
17-feb-18													
18-feb-18	2	4	54,129	54,292	179	1	163	7	1,093	44.54	112	39.77	60.23
19-feb-18	2	4	54,292	54,446	169	1	154	6.8	1,093	42.08	112	37.57	62.43
20-feb-18	2	4	54,446	54,611	181	1	165	6.4	1,093	45.09	112	40.26	59.74
21-feb-18	2	4	54,611	54,767	171	1	156	7.2	1,093	42.63	112	38.06	61.94
22-feb-18	2	4	54,767	54,935	185	1	168	6.3	1,093	45.91	112	40.99	59.01
23-feb-18													
24-feb-18													
25-feb-18	2	4	54,935	55,091	171	1	156	6.7	1,093	42.63	112	38.06	61.94
26-feb-18	2	4	55,091	55,247	171	1	156	7	1,093	42.63	112	38.06	61.94
27-feb-18	2	4	55,247	55,422	192	1	175	6.1	1,093	47.82	112	42.70	57.30
28-feb-18	2	4	55,422	55,608	204	1	186	7.3	1,093	50.82	112	45.38	54.62
				3,200			3200						

3,516

Operadores

Revisó:

Julio Figueroa

Aprobó:

Astaburuaga Correa

Sebastián

Responsable

Fecha:

Fecha: